

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50441515

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i>
12103636/FL260218	ZTW1--50213338 001	29.07.2019	(day/mo/yr)

Genehmigungsinhaber *License Holder*
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd.,
Wugu District, New Taipei City
24891
Taiwan

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1419071165

Geprüft nach *Tested acc. to*
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbauschaltnetzteil (Switching Power Supply)

Bezeichnung (Type Designation)	: HRPX-600-Y (MEAN WELL)	10
X steht für (stands for)	: G oder freibleibend (or blank)	1
Y steht für (stands for)	: 3.3, 5, 7.5, 12, 15, 24, 36, 48 36 oder (or) 48	1
Nennspannung (Rated Voltage)	: AC 100-240V, 50/60Hz	
Nennstrom (Rated Current)	: 8.5A	
Ausgang (Output)	: siehe Aufbau-Übersicht (see constructional dataform)	
max. Betriebshöhe (max. Operating Altitude)	: 4000m	
max. Umgebungstemperatur (max. Ambient Temperature)	: 50°C	
Schutzklasse (Protection Class)	: I	
Verschmutzungsgrad (Pollution Degree)	: 2	

12

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Dipl.-Ing. F. Stoelzel

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50441515

Blatt *Sheet*
0002

Ihr Zeichen *Client Reference*
12103636/FL260218

Unser Zeichen *Our Reference*
ZTW1--50213338 001

Ausstellungsdatum *Date of Issue*
29.07.2019
(day/mo/yr)

Genehmigungsinhaber *License Holder*
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd.,
Wugu District, New Taipei City
24891
Taiwan

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1419071165

Geprüft nach *Tested acc. to*
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbauschaltnetzteil (Switching Power Supply)

wie Blatt (as page) 01

Ergänzung
(Addition)

Bezeichnung (Type Designation)	: HRP-600-24GR (MEAN WELL)	1
	: HRP-600-48UN (MEAN WELL)	1
	: HRP-600-60SI (MEAN WELL)	1

Ausgang
(Output) : siehe Aufbau-Übersicht
(see constructional dataform)

3

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Dipl.-Ing. F. Stoelzel

Anlage Fertigungsstättenliste
/Attachment List of Factories



R 50441515 0001

1 MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd.,
Wugu District, New Taipei City
24891
Taiwan

2 SuZhou MEAN WELL Technology
Co., Ltd.
No. 77, Jian-min Road, Dong-qiao,
Pan-yang Ind. Park, Huang-dai Town,
Xiang-cheng District Suzhou,
Jiangsu 215152
P. R. China

3 MEAN WELL (GUANGZHOU) ELECTRONICS
CO., LTD HUADU BRANCH
No. 11 Jingu South Road,
Huadong Town, Huadu District,
Guangzhou 510890
P. R. China

TÜVRheinland

Dieser Anhang ersetzt den Vorgänger vom/
This annex replaces the previous annex dated

Datum / Date 29.07.2019

Zertifizierungsstelle
/ Certification Body

A handwritten signature in blue ink, appearing to be 'F. Staelzel'.

Dipl.-Ing. F. Staelzel



Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50441515

Blatt *Sheet*
0003

Ihr Zeichen *Client Reference*
244065229

Unser Zeichen *Our Reference*
ZTW1-MLQ-50213338 002

Ausstellungsdatum *Date of Issue*
09.09.2020
(day/mo/yr)

Genehmigungsinhaber *License Holder*
MEAN WELL Enterprises Co., Ltd.
No. 28, Wuguan 3rd Rd.,
Wugu District,
New Taipei City 24891
Taiwan

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1419071165

Geprüft nach *Tested acc. to*
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbauschaltnetzteil (Switching Power Supply)

as page 0001

Addition

Type Designation	: HRP-600N-Z	2
	(Z = 12, 24, 36, 48)	
Trademark	: MEAN WELL	
Rated Input	: 100-240VAC, 8.5A, 50/60Hz	
Rated Output	: refer to Appendix No. 1.1	
Protection Class	: Class I	
Max. Operating Altitude	: 5000m	
Max. Operating Temperature	: +50°C	

Remark:

The installation has to be carried out according to the installation instructions accompanying the product.

2



ANLAGE (Appendix): 1.1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Mark Chen

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50441515

Blatt *Sheet*
0004

Ihr Zeichen *Client Reference*
245761092

Unser Zeichen *Our Reference*
ZTW1-Yangede-50213338

Ausstellungsdatum *Date of Issue*
003 10.01.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*

MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd.,
Wugu District,
New Taipei City 24891
Taiwan

Fertigungsstätte *Manufacturing Plant*

Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbauschaltnetzteil (Switching Power Supply)

as page 0001

Addition

Type Designation : HRP-600N3-Z
(Z = 12, 24, 36, 48)
Trademark : MEAN WELL
Rated Input : AC 100-240V, 8.5A, 50/60Hz
Rated Output : refer to Appendix No. 1.2
Protection Class : Class I
Max. Operating Altitude : 5000m
Max. Operating Temperature : +50°C

Remark:

The installation has to be carried out according to the installation instructions accompanying the product.

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935



Mark Chen

Anlage Fertigungsstättenliste
/Attachment List of Factories



R 50441515 0001

Anlagenrevision / Annex revision

1


- | | |
|---|---|
| <p>1 Suzhou MEAN WELL Technology Co., Ltd.
No. 77, Jian-Min Road,
Dong-Qiao, Pan-Yang Ind. Park,
Huang-Dai Town, Xiang-Cheng District,
Suzhou
215152 Jiangsu
P.R. China</p> | <p>2 MEAN WELL (GUANGZHOU) Electronics
Co., Ltd.
No. 11 Jingu South Road, Huadu District,
Guangzhou
510890 Guangdong
P.R. China</p> |
| <p>3 MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd.,
Wugu District,
New Taipei City 24891
Taiwan</p> | |

Dieser Anhang ersetzt den Vorgänger vom/
This annex replaces the previous annex dated

Datum / Date 29.07.2019



Zertifizierungsstelle
/ Certification Body


Mark Chen

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50441515

Blatt Sheet
0005

Ihr Zeichen Client Reference
245785455

Unser Zeichen Our Reference **Ausstellungsdatum Date of Issue**
ZTW1-Yangede-50213338 004 15.11.2022 (day/mo/yr)

Genehmigungsinhaber License Holder
MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd.,
Wugu District,
New Taipei City 24891
Taiwan

Fertigungsstätte Manufacturing Plant
Refer to latest revision
of the annex list of factories

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1419071165

Geprüft nach Tested acc. to
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbauschaltnetzteil (Switching Power Supply) [®]

as page 0001

Change

refer to Appendix No. 1.3

ANLAGE (Appendix): 1.3

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

Mark Chen

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

**Anlage Fertigungsstättenliste
/Attachment List of Factories**



R 50441515 0005

Anlagenrevision / Annex revision

1

1 Suzhou MEAN WELL Technology Co., Ltd.
No. 77, Jian-Min Road,
Dong-Qiao, Pan-Yang Ind. Park,
Huang-Dai Town, Xiang-Cheng District,
Suzhou
215152 Jiangsu
P.R. China

2 MEAN WELL (GUANGZHOU) Electronics
Co., Ltd.
No. 11 Jingu South Road, Huadu District,
Guangzhou
510890 Guangdong
P.R. China

3 MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd.,
Wugu District,
New Taipei City 24891
Taiwan

A large, faint watermark of the TÜVRheinland logo is centered on the page. It consists of the stylized triangle logo above the text 'TÜVRheinland' with a registered trademark symbol (®) to its right.


TÜVRheinland®

Dieser Anhang ersetzt den Vorgänger vom/
This annex replaces the previous annex dated

Datum / Date 15.11.2022



Zertifizierungsstelle
/ Certification Body


Mark Chen