



中国国家强制性产品认证证书

证书编号：2015010907760048

认证委托人名称及地址
苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

生产者名称及地址
明纬企业股份有限公司
新北市五股区五权三路 28 号

生产企业名称及地址
苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

产品名称和系列、型号、规格
开关电源
见附页，仅适用于海拔 2000 米及以下

产品标准和技术要求
GB 17625.1-2022 (A 类) ;GB 4943.1-2022;GB/T 9254.1-2021
上述产品符合《强制性产品认证实施规则 电子产品及安全附件》
(CNCA-C09-01:2023) 的要求，特发此证。

发证日期：2024 年 11 月 27 日 有效期至：2029 年 11 月 26 日

本证书为变更证书，证书首次颁发日期：2015 年 03 月 17 日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站 (www.cnca.gov.cn) 查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2015010907760048

证书附页：第 1 页 共 1 页

RS-50-X(X=3.3,5,12,15,24,48)；输入：100 - 240VAC，50/60Hz，1.3 A；直流输出如下表。

型号	直流输出规格
RS-50-3.3	3.3V,10A
RS-50-5	5V,10A
RS-50-12	12V,4.2A
RS-50-15	15V,3.4A
RS-50-24	24V,2.2A
RS-50-48	48V,1.1A

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2015010907760048

NAME AND ADDRESS OF THE APPLICANT
SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

NAME AND ADDRESS OF THE MANUFACTURER
MEAN WELL ENTERPRISES CO. , LTD

NO.28 , Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan, 24891

NAME AND LOCATION OF THE FACTORY
SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

PRODUCT NAME, MODEL AND SPECIFICATION

AC/DC POWER SUPPLY

See appendix, Altitude up to 2000m

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022 (Class A) ; GB 4943.1-2022; GB/T 9254.1-2021

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C09-01:2023).

Valid from: Nov.27,2024

Valid until: Nov.26,2029

Date of original issued: Mar.17,2015

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION


本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2015010907760048

Appendix : Page 1 of 1

RS-50-X(X=3.3,5,12,15,24,48) ; Input : 100 - 240VAC , 50/60Hz , 1.3 A ; DC Output see table

Model	DC Output
RS-50-3.3	3.3V,10A
RS-50-5	5V,10A
RS-50-12	12V,4.2A
RS-50-15	15V,3.4A
RS-50-24	24V,2.2A
RS-50-48	48V,1.1A



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.