

# CERTIFICATE

Issued to:  
Applicant:  
**MEAN WELL Enterprises Co., Ltd.**  
No.28, Wuquan 3rd Rd, Wugu District  
24891 New Taipei City, Taiwan

Licensee:  
**MEAN WELL Enterprises Co., Ltd.**  
No.28, Wuquan 3rd Rd, Wugu District  
24891 New Taipei City, Taiwan

Product : Independent LED driver  
Trade name(s) : MEAN WELL  
Type(s)/model(s) : SLD-50-12, SLD-50-24 and SLD-50-56

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 61347-1:2015, EN 62384:2006/A1:2009 and EN 62384:2006
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2175773


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 9 September 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-110131

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



R Zhou  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Independent LED driver
Trade name(s)	: MEAN WELL
Type(s)/model(s)	: SLD-50-12, SLD-50-24 and SLD-50-56
Rated input voltage	: 110-240 V~
Rated input current	: 0,6 A
Rated frequency	: 50/60 Hz
Max. case temperature (tc)	: 90 °C
Ambient temperature (ta)	: 40 °C when input: 110-200 V~, 50 °C when input: 200-240 V~
Power factor	: 0,95
Class of insulation	: Class II
Degree of protection	: IP20
Additional information	: SELV, Thermal, short-circuit and overload protection, MM mark.

**TESTS****Test requirements**

EN 61347-2-13:2014  
EN 61347-2-13:2014/A1:2017  
EN 61347-1:2015  
EN 62384:2006/A1:2009  
EN 62384:2006

**Test result**

The test results are laid down in DEKRA test file 435631700.

**Additional information**

The list of components is laid down at test report 4356317.50 + 4356317.51.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

MEAN WELL (GUANGZHOU) Electronics Co.,Ltd. Huadu Branch  
No.11 Jingu South Road, Huadong Town, Huadu District,  
Guangzhou 510890, Guangdong, China

Trade name(s) : MEAN WELL stands for



Model list:

Model No	Input voltage (V)	Input current (A)	Output rating	Remark
SLD-50-12	110-240	0,6	Constant current mode: 13 Vdc max., 8,4-12 Vdc, 4,2 A, Rated power: 50,4 W Constant voltage mode: 12 Vdc, 0-4,2 A, Rated Power: 50,4 W	Constant voltage + Constant current
SLD-50-24	110-240	0,6	Constant current mode: 25 Vdc max., 16,8-24 Vdc, 2,1 A, Rated power: 50,4 W Constant voltage mode: 24 Vdc, 0-2,1 A, Rated Power: 50,4 W	Constant voltage + Constant current
SLD-50-56	110-240	0,6	60 Vdc max., 30-56 Vdc, 0,9-1,4 A, Rated power: 50,4 W	Constant current